

Licence # 6163
Full licence available at: <http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=38801&SYSUID=1&LICID=6163>
Tomago Aluminium Company Limited
638 Tomago Road, Tomago NSW 2322

Monitoring Period: Nov 2025 - Oct 2026

EPA Monitoring Point	1	2	3	4	5	6	7	8	9	30
Descriptor	Line 1 West Stack	Line 1 East Stack	Line 2 West Stack	Line 2 East Stack	Anode Plant 1 Stack	Anode Plants 2&3 Stack	Line 3 West Stack	Line 3 East Stack	Line 1&2 Extension Stack	Total smelter emissions sum of point sources
Total Solid Particles, mg/m3	6.4	4.6	3.3	NYA	NYA	NYA	8.8	4.0	1.2	
Monitoring frequency requirement	Annually	Annually	Annually	Annually	Annually	Annually	Annually	Annually	Annually	
Date Tested	24/03/2026	30/06/2026	29/01/2026				23/04/2026	28/11/2025	12/06/2026	
Date Results Available	8/05/2026	3/07/2027	2/02/2026				5/05/2026	2/12/2025	23/06/2026	
Date Published	14/05/2026	14/07/2026	13/02/2026				14/05/2026	10/12/2025	14/07/2026	
Licence Limit, mg/m3	50	50	50	50	50	50	50	50	50	
Exceedance?	No	No	No	NYA	NYA	NYA	No	No	No	
Nitrogen Oxides, g/m3					NYA	NYA				
Monitoring frequency requirement					Annually	Annually				
Date Tested										
Date Results Available										
Date Published										
Licence Limit, g/m3					2.0	2.0				
Exceedance?					NYA	NYA				
Total PAH's as Benzo(a)pyrene equivalent, mg/m3					NYA	NYA				
Monitoring frequency requirement					Annually	Annually				
Date Tested										
Date Results Available										
Date Published										
Licence Limit, mg/m3					0.005	0.005				
Exceedance?					NYA	No				
Fluoride, kg F / t Al										
Monitoring frequency requirement										Calculation at End of Licence Year
Date Results Available										
Date Published										
Licence Limit, mg/m3										0.56**
Exceedance?										NYA

Notes:
There are no applicable licence limits for Total PAH's
mg/m3 = milligrams per cubic metre
g/m3 = grams per cubic metre
kg F / t Al = kilograms fluoride per tonne aluminium produced
**This limit may be exceeded to a maximum of 0.6 one year out of every five
NYA = Not Yet Available
Comments on exceedances: _____

Licence # 6163

Full licence available at: <http://www.epa.nsw.gov.au/prpoeoapp/ViewPOELicence.aspx?DOCID=38801&SYSUID=1&LICID=6163>

Tomago Aluminium Company Limited
638 Tomago Road, Tomago NSW 2322

Monitoring Period:

Nov 2025 - Oct 2026

EPA Monitoring Point	31	32	33	34
Descriptor	No.1 Paste Plant, Pitch Circuit Stack	No.1 Paste Plant, Proportioning Circuit Stack	No.2 Paste Plant, Pitch Circuit Stack	No.2 Paste Plant, Proportioning Circuit Stack
Total Solid Particles, mg/m3	NYA	NYA	NYA	NYA
Monitoring frequency requirement	Annually	Annually	Annually	Annually
Date Tested				
Date Results Available				
Date Published				
Licence Limit, mg/m3	50	50	50	50
Exceedance?	NYA	NYA	NYA	NYA
Total PAH's as Benzo(a)pyrene equivalent, mg/m3	NYA	NYA	NYA	NYA
Monitoring frequency requirement	Annually	Annually	Annually	Annually
Date Tested				
Date Results Available				
Date Published				
Licence Limit, mg/m3	0.005	0.005	0.005	0.005
Exceedance?	NYA	NYA	NYA	NYA

Notes:

mg/m3 = milligrams per cubic metre

NYA = Not Yet Available

Comments on exceedances:

Licence # 6163

Full licence available at:

<http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=38801&SYSUID=1&LICID=6163>

Tomago Aluminium Company Limited

638 Tomago Road, Tomago NSW 2322

Monitoring Period:

Nov 2025 - Oct 2026

EPA Monitoring Point	38	
Descriptor	Deline/Regain Spent Potliner Dust Filter	
	Total Solid Particles, mg/m3	Fine Particulates, mg/m3
	0.5	0.1
Monitoring frequency requirement	Annually	Annually
Date Tested	3/02/2026	3/02/2026
Date Results Available	4/02/2026	4/02/2026
Date Published	13/02/2026	13/02/2026
Licence Limit, mg/m3	20	10
Exceedance?	No	No

Notes:

mg/m3 = milligrams per cubic metre

NYA = Not Yet Available

Comments on exceedances:_____